

**MOREPEN LABORATORIES LIMITED  
UNIT-IV, BADDI****E.T.P. FINAL OUTLET WATER ANALYSIS CERTIFICATE**

Date of reporting : 06-OCT-21

Date of Sampling : 04-OCT-21

<b>Sr.No</b>	<b>Parameter</b>	<b>Result</b>	<b>Limit</b>	<b>Remarks</b>
1	pH	7.58	6.5-8.5	Ok
2	COD	190.80	250 mg/l	Ok
3	TDS	1470	2100 mg/l	Ok
4	TSS	48	100 mg/l	Ok

  
06-Oct-21

**MOREPEN LABORATORIES LIMITED  
UNIT-IV, BADDI****AIR MONITORING TEST CERTIFICATE**

Date of Reporting	06-Oct-21	page no 1 of 1
Factory / Lab	Morepen Laboratories Ltd Unit-IV, Morepen Village, Nalagarh Road, Near Baddi Distt. Solan (H.P.) Pin- 173205 Tel: 01795-276201-03, Fax: 01795-276204	
Type of sample	Ambient Air Monitoring for RSPM, SO <sub>2</sub> , NO <sub>X</sub>	
Packing & Marking	Ambient Air Monitoring	
Seal	Open	
Model of Receipt	Sampling by Laboratory	
of sample		
Date of sampling	05-Oct-21	
Date of Receipt sample	05-Oct-21	Period of Analysis: 2 Days
Sampling by	Mr. Navdeep Rawat	
Sample location	Near main gate	
Remarks	Clear Sky	

Sr. No	Test	Unit	Results	Limit
1	Particulate Matter (PM10)	ug/m <sup>3</sup>	69.71 ug/m <sup>3</sup>	100
2	Sulphur Dioxide (SO <sub>2</sub> )	ug/m <sup>3</sup>	26.41S ug/m <sup>3</sup>	80
3	Nitrogen Oxide (NO <sub>X</sub> )	ug/m <sup>3</sup>	67.87 ug/m <sup>3</sup>	80

  
06-Oct-21