

**MOREPEN**  
**MOREPEN LABORATORIES LIMITED**  
**UNIT-IV, BADDI**

E.T.P. FINAL OUTLET WATER ANALYSIS CERTIFICATE

Date of Reporting : 10-MAY-22

Date of Sampling : 09-MAY-22

Sr.No	Parameter	Result	Limit	Remarks
1	pH	7.15	6.5-8.5	Ok
2	COD	152.32	250 mg/l	Ok
3	TDS	1610	2100 mg/l	Ok
4	TSS	40	100 mg/l	Ok

#

**MOREPEN****MOREPEN LABORATORIES LIMITED  
UNIT-IV, BADDI****E.T.P. FINAL OUTLET WATER ANALYSIS CERTIFICATE**

Date of Reporting : 10-MAY-22

Date of Sampling : 02-MAY-22

<b>Sr.No</b>	<b>Parameter</b>	<b>Result</b>	<b>Limit</b>	<b>Remarks</b>
1	pH	7.35	6.5-8.5	Ok
2	COD	148.09	250 mg/l	Ok
3	TDS	1610	2100 mg/l	Ok
4	TSS	32	100 mg/l	Ok