

MOREPEN LABORATORIES LIMITED
UNIT-IV, BADDI

E.T.P. FINAL OUTLET WATER ANALYSIS CERTIFICATE

Date of Reporting : 17-Aug-21

Date of Sampling : 15-Aug-22

Sr.No	Parameter	Result	Limit	Remarks
1	pH	7.00	6.5-8.5	Ok
2	COD	160.00	250 mg/l	Ok
3	TDS	1225	2100 mg/l	Ok
4	TSS	45	100 mg/l	Ok