

MOREPEN LABORATORIES LIMITED
UNIT-IV, BADDI

E.T.P. FINAL OUTLET WATER ANALYSIS CERTIFICATE

Date of Reporting : 31-Aug-22

Date of Sampling : 29-Aug-22

Sr.No	Parameter	Result	Limit	Remarks
1	pH	7.08	6.5-8.5	Ok
2	COD	164.73	250 mg/l	Ok
3	TDS	1340	2100 mg/l	Ok
4	TSS	36	100 mg/l	Ok