

**MOREPEN LABORATORIES LIMITED**  
**UNIT-IV, BADDI**

**E.T.P. FINAL OUTLET WATER ANALYSIS CERTIFICATE**

Date of Reporting : 12-Sep.-22

Date of Sampling : 10-Sep.-22

<b>Sr.No</b>	<b>Parameter</b>	<b>Result</b>	<b>Limit</b>	<b>Remarks</b>
1	pH	7.00	6.5-8.5	Ok
2	COD	196.00	250 mg/l	Ok
3	TDS	1184	2100 mg/l	Ok
4	TSS	68	100 mg/l	Ok