

MOREPEN LABORATORIES LIMITED
UNIT-IV, BADDI

E.T.P. FINAL OUTLET WATER ANALYSIS CERTIFICATE

Date of Reporting : 09-Nov.-22

Date of Sampling : 07-Nov.22

Sr.No	Parameter	Result	Limit	Remarks
1	pH	7.00	6.5-8.5	Ok
2	COD	180.00	250 mg/l	Ok
3	TDS	1605	2100 mg/l	Ok
4	TSS	67	69 mg/l	Ok